



General Notes:

1. The reduced pressure assembly shall be in accordance with the University of Southern California Foundation for Cross-Connection Control's most current "List of Approved Backflow Assemblies", AWWA C511-17, and pre-approved by MWD prior to installation.
2. All new & replacement assemblies on potable water service lines shall be lead-free in accordance with California Health & Safety Code 116875.
3. Location of assembly to be at District meter. Exceptions to be approved by MWD prior to installation.
4. There shall be no connections between the District meter and the backflow assembly.
5. Assembly shall be horizontal and level unless approved for other orientations and pre-approved by MWD prior to installation.
6. Thrust blocks to be per MWD CS 113.
7. Backflow assembly to be tested and approved by a certified tester. MWD meter shall remain locked, except for backflow testing purposes, until a satisfactorily completed backflow test report is received at the Montecito Water District office (583 San Ysidro Road, Montecito).
8. Maintain minimum 12-inch clearance from any structure.
9. Pipe supports with concrete footings (not shown) required as needed.

REDUCED PRESSURE BACKFLOW ASSEMBLY FOR METER PROTECTION