

ADDENDUM 1: Water Main Repair at Fernald Point Lane Bridge

MONTECITO WATER DISTRICT

December 17, 2020

ADDENDUM NO. 1

TO REQUEST FOR PROPOSALS
Water Main Repairs at Fernald Point Lane Bridge

DATED November 25, 2020

Notice is hereby given to bidders that this addendum is issued to make changes to the contract documents, construction drawings, and construction specifications. The following changes shall be made to the contract documents, construction drawings, and construction specifications by the Contractor.

ADDENDUM 1-1: Q&A

Q: What are the required specs for the temporary HDPE pipe?

A: The temporary 6" HDPE shall be SDR 9 or better.

Q: What is the projected schedule for the county bridge project? Will phase 1 need to happen before the county's temporary bridge is installed?

A: The county has not set a schedule. This project is contingent on the county proceeding with their bridge replacement project. If they do proceed, it is up to the contractor to coordinate the schedule with the county.

APPROVED:



David Wong, E.I.T.
Engineering Assistant