

**MONTECITO WATER DISTRICT**

July 19, 2021

**ADDENDUM NO. 3**

TO REQUEST FOR PROPOSALS  
**East Valley Road Water Main Replacement**  
**Project # P41**

DATED June 2021

Notice is hereby given to bidders that this addendum is issued to make changes to the contract documents, construction drawings, and construction specifications. The following changes shall be made to the contract documents, construction drawings, and construction specifications by the Contractor.

**ADDENDUM 2:**

**Q&A**

- Q1. Is there a bid item for the Caltrans requirements of dual survey permit and 3D Vector as build requirements?
- A1. Survey work for as-builts is not in the scope of work for this project.
- Q2. We are aware of a project to pave the Highway 192 with hot mixed rubberized asphalt. Will this mix be required for this project?
- A2. No need for a rubberized asphalt mix. Use HMA Type A in compliance with 2018 CalTrans Standard Specification 39-2.

APPROVED:



David Wong, E.I.T.  
Engineering Assistant